

# RIVERBANK ACOUSTICAL LABORATORIES

1512 S. BATAVIA AVENUE  
GENEVA, ILLINOIS 60134

Alion Science and Technology

630/232-0104  
FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

## TEST REPORT

FOR: Verco Manufacturing Co.  
Phoenix, AZ.

Sound Absorption  
RAL™-A14-049

CONDUCTED: 26 February 2014

Page 1 of 6

ON: #43 - N24 Web Perforated Metal Deck - Plain 0.75pcf Fiberglass 2.375"x3" Over 0.5"  
DensDeck over 2"Poly ISO Board

### TEST METHOD

The test method conformed explicitly with the requirements of the ASTM Standard Test Method for Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method: ASTM C423-09a and E795-05. Riverbank Acoustical Laboratories has been accredited by the U.S. Department of Commerce, National Institute of Standards and Technology (NIST) under the National Voluntary Laboratory Accreditation Program (NVLAP) for this test procedure (NVLAP Lab Code: 100227-0). A description of the measuring procedure and room qualifications is available separately.

### DESCRIPTION OF THE SPECIMEN

The test specimen was designated by the manufacturer as #43 - N24 Web Perforated Metal Deck - Plain 0.75pcf Fiberglass 2.375"x3" Over 0.5" DensDeck over 2"Poly ISO Board. A visual inspection by Riverbank staff verified the manufacturer's description. The thickness of the metal was measured as 0.97 mm (0.04 in). The perforation in each web (sides only), measured as 158.75 mm (6.25 in) (bottom) and 133.35 mm (5.25 in) (top) were as follows: 4.0 mm (0.16 in) diameter, round perforations with 11.0 mm (0.43 in) staggered centers (11.99% open area in perforated region). The acoustic core of each web consisted of un-encapsulated 0.75 pcf fiberglass strips measured as 2.74 m (108 in) long by 60.45 mm (2.38 in) wide and 76.2 mm (3.0 in) thick. The entire metal deck was backed by DensDek and polyisocyanurate roof board (dense foam panels with reinforced felt facing) measured as 12.7 mm (0.5 in) and 50.8 mm (2.0 in) thick, respectively.

The specimen consisted of 4 sections of web-perforated metal deck, each measured as 2.74 m (108.0 in) long by 0.61 m (24.5 in) wide and 76.2 mm (3.0 in) thick. Laid together as a single rectangular patch, the overall dimensions of the specimen as measured were 2.74 m (108.00 in.) long by 2.44 m (96.00 in.) wide and 139.70 mm (5.50 in.) thick. The area used in the calculations was 6.69 m<sup>2</sup> (72.00 ft<sup>2</sup>). The weight of the entire specimen as measured was 162.96 kg (359.25 lbs), an average of 24.36 kg/m<sup>2</sup> (4.99 lbs/ft<sup>2</sup>).

The specimen was tested in the laboratory's 292.0 m<sup>3</sup> (10,311.0 ft<sup>3</sup>) test chamber. The room temperature at the time of the test was 21.1±0.1°C (69.9±0.2°F) and 62.6±0.0% relative humidity. The atmospheric pressure was 98.9 kPa.



NVLAP LAB CODE 100227-0

RAL IS ACCREDITED BY THE US DEPARTMENT OF COMMERCE, NATIONAL VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SPECIFIC ACOUSTICAL TEST METHODS. THE LABORATORY'S ACCREDITATION OR ANY OF ITS TEST REPORTS IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL OR ENDORSEMENT BY NIST OR RAL.

THIS REPORT SHALL NOT BE MODIFIED OR PARTIALLY REPRODUCED WITHOUT THE WRITTEN APPROVAL OF RAL.

THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR MEASUREMENT; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SPECIMEN.

# RIVERBANK ACOUSTICAL LABORATORIES

1512 S. BATAVIA AVENUE  
GENEVA, ILLINOIS 60134

Alion Science and Technology

630/232-0104  
FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

## TEST REPORT

Verco Manufacturing Co.  
26 February 2014

RAL™-A14-049  
Page 2 of 6



Figure 1 - Specimen mounted in the test chamber.



Figure 2 - Detail of the test specimen.



NVLAP LAB CODE 100227-0

RAL IS ACCREDITED BY THE US DEPARTMENT OF COMMERCE, NATIONAL VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SPECIFIC ACOUSTICAL TEST METHODS. THE LABORATORY'S ACCREDITATION OR ANY OF ITS TEST REPORTS IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL OR ENDORSEMENT BY NIST OR RAL.

THIS REPORT SHALL NOT BE MODIFIED OR PARTIALLY REPRODUCED WITHOUT THE WRITTEN APPROVAL OF RAL.

THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR MEASUREMENT; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SPECIMEN.

# RIVERBANK ACOUSTICAL LABORATORIES

1512 S. BATAVIA AVENUE  
GENEVA, ILLINOIS 60134

Alion Science and Technology

630/232-0104  
FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

## TEST REPORT

Verco Manufacturing Co.  
26 February 2014

RAL™-A14-049  
Page 3 of 6

### MOUNTING A

The test specimen was laid directly against the test surface. The perimeter was sealed using wood and metal framing.

### TEST RESULTS

| 1/3 Octave Center<br>Frequency<br>(Hz) | Absorption<br>Coefficient<br>(Sabins / ft <sup>2</sup> ) | Total Absorption<br>In Sabins |
|--|--|-------------------------------|
| 100                                    | 0.07   | 4.75                          |
| ** 125                                 | 0.21   | 14.90                         |
| 160                                    | 0.23   | 16.23                         |
| 200                                    | 0.28   | 20.14                         |
| ** 250                                 | 0.45   | 32.74                         |
| 315                                    | 0.67   | 48.33                         |
| 400                                    | 0.71   | 51.43                         |
| ** 500                                 | 0.77   | 55.68                         |
| 630                                    | 0.76   | 54.97                         |
| 800                                    | 0.86   | 62.09                         |
| ** 1000                                | 0.87   | 62.56                         |
| 1250                                   | 0.72   | 52.09                         |
| 1600                                   | 0.58   | 41.58                         |
| ** 2000                                | 0.50   | 36.06                         |
| 2500                                   | 0.38   | 27.29                         |
| 3150                                   | 0.37   | 26.66                         |
| ** 4000                                | 0.32   | 22.78                         |
| 5000                                   | 0.31   | 22.20                         |

**SAA = 0.63**

**NRC = 0.65**



NVLAP LAB CODE 100227-0

RAL IS ACCREDITED BY THE US DEPARTMENT OF COMMERCE, NATIONAL VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SPECIFIC ACOUSTICAL TEST METHODS. THE LABORATORY'S ACCREDITATION OR ANY OF ITS TEST REPORTS IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL OR ENDORSEMENT BY NIST OR RAL.

THIS REPORT SHALL NOT BE MODIFIED OR PARTIALLY REPRODUCED WITHOUT THE WRITTEN APPROVAL OF RAL.

THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR MEASUREMENT; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SPECIMEN.

# RIVERBANK ACOUSTICAL LABORATORIES

1512 S. BATAVIA AVENUE  
GENEVA, ILLINOIS 60134

Alion Science and Technology

630/232-0104  
FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

## TEST REPORT



Verco Manufacturing Co.  
26 February 2014

RAL™-A14-049  
Page 4 of 6

### TEST RESULTS (Continued)

The sound absorption average (SAA) is defined as a single number rating, the average, rounded to the nearest 0.01, of the sound absorption coefficient of a material for the twelve one-third octave bands from 200 through 2500 Hz, inclusive.

The noise reduction coefficient (NRC) is defined from previous versions of this same test method as the average of the coefficients at 250, 500, 1000, and 2000 Hz, expressed to the nearest integral multiple of 0.05.

Tested by  Approved by   
*Experimentalist* *Laboratory Manager*



NVLAP LAB CODE 100227-0

RAL IS ACCREDITED BY THE US DEPARTMENT OF COMMERCE, NATIONAL VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SPECIFIC ACOUSTICAL TEST METHODS. THE LABORATORY'S ACCREDITATION OR ANY OF ITS TEST REPORTS IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL OR ENDORSEMENT BY NIST OR RAL.

THIS REPORT SHALL NOT BE MODIFIED OR PARTIALLY REPRODUCED WITHOUT THE WRITTEN APPROVAL OF RAL.

THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR MEASUREMENT; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SPECIMEN.

# RIVERBANK ACOUSTICAL LABORATORIES

1512 S. BATAVIA AVENUE  
GENEVA, ILLINOIS 60134

Alion Science and Technology

630/232-0104  
FOUNDED 1918 BY  
WALLACE CLEMENT SABINE


## TEST REPORT

Verco Manufacturing Co.  
26 February 2014

RAL™-A14-049  
Page 5 of 6

### SOUND ABSORPTION REPORT

#43 - N24 Web Perforated Metal Deck - Plain 0.75pcf Fiberglass 2.375"x3" Over  
0.5" DensDeck over 2" Poly ISO Board



**SAA = 0.63**

**NRC = 0.65**



NVLAP LAB CODE 100227-0

RAL IS ACCREDITED BY THE US DEPARTMENT OF COMMERCE, NATIONAL VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SPECIFIC ACOUSTICAL TEST METHODS. THE LABORATORY'S ACCREDITATION OR ANY OF ITS TEST REPORTS IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL OR ENDORSEMENT BY NIST OR RAL.

THIS REPORT SHALL NOT BE MODIFIED OR PARTIALLY REPRODUCED WITHOUT THE WRITTEN APPROVAL OF RAL.

THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR MEASUREMENT; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SPECIMEN.



# RIVERBANK ACOUSTICAL LABORATORIES

1512 S. BATAVIA AVENUE  
GENEVA, ILLINOIS 60134

Alion Science and Technology

630/232-0104  
FOUNDED 1918 BY  
WALLACE CLEMENT SABINE

## TEST REPORT

Verco Manufacturing Co.  
26 February 2014

RAL™-A14-049  
Page 6 of 6

### Appendix to ASTM C423 Sound Absorption Test **Extended Frequency Range Data**

Product Description: #43 - N24 Web Perforated Metal Deck - Plain 0.75pcf Fiberglass 2.375"x3"  
Over 0.5" DensDeck over 2" Poly ISO Board (See Full Report)

Riverbank Acoustical Laboratories is accredited to perform sound absorption coefficient measurements for the frequency range of 100Hz to 5,000Hz. However, we calculate sound absorption values at additional test frequencies as a service to our clients.

Although these measurements were made in accordance with the procedures described in ASTM C423-09a, they do not qualify as part of the standard. Since the results are representative of the test environment only, they are unofficial and intended for research and development guidelines rather than for commercial purposes. The sound absorption values at additional frequencies were as follows:

#### **RAL-A14-049**

| <b>1/3 Octave Center Frequency</b><br><b>(Hz)</b> | <b>Absorption</b><br><b>Coefficient</b><br><b>(Sabins / ft<sup>2</sup>)</b> | <b>Total Absorption</b><br><b>(Sabins)</b> |
|---|---|--|
| 40  | 0.09  | 6.47                                       |
| 50  | -0.02   | -1.12                                      |
| 63  | -0.04   | -3.21                                      |
| 80  | -0.01   | -0.97                                      |
| 6300  | 0.36  | 25.99                                      |
| 8000  | 0.36  | 25.68                                      |
| 10000   | 0.19  | 13.98                                      |



NVLAP LAB CODE 100227-0

RAL IS ACCREDITED BY THE US DEPARTMENT OF COMMERCE, NATIONAL VOLUNTARY LABORATORY ACCREDITATION PROGRAM FOR SPECIFIC ACOUSTICAL TEST METHODS. THE LABORATORY'S ACCREDITATION OR ANY OF ITS TEST REPORTS IN NO WAY CONSTITUTES OR IMPLIES PRODUCT CERTIFICATION, APPROVAL OR ENDORSEMENT BY NIST OR RAL.

THIS REPORT SHALL NOT BE MODIFIED OR PARTIALLY REPRODUCED WITHOUT THE WRITTEN APPROVAL OF RAL.

THE RESULTS REPORTED APPLY ONLY TO THE SPECIFIC SAMPLE SUBMITTED FOR MEASUREMENT; RAL ASSUMES NO RESPONSIBILITY FOR THE PERFORMANCE OF ANY OTHER SPECIMEN.